

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

AHF, LLC dba AHF Products

3840 Hempland Road, P.O. Box 566, Mountville, Pennsylvania 17554, United States

For the following product(s):

Flooring Adhesives:

Armstrong Flooring S-202 SDT Adhesive for Static Dissipative Tile, Armstrong Flooring S-319 Roll Strong, Armstrong Flooring S-515 Clear Thin Spread Floor Tile Adhesive

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 Version 4.2 – 2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017).

Highest Specified Product Application Amount: 412 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017) Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-08496

Valid from: September 01, 2025 to November 30, 2026

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



Diana Kirsanova Phillips, Chief of Staff to the CEO / Chief Assurance Officer
SCS Global Services