

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400 Fax (03) 9371 2499

## TEST REPORT

**Client :** Armstrong Flooring Pty Ltd  
29-39 Mills Road  
Braeside VIC 3195

**Test Number :** 16-006469  
**Issue Date :** 16/12/2016  
**Print Date :** 16/12/2016  
**Order Number :** 117259

**Sample Description** Clients Ref : "Fitnice Woven Flooring, Memphis"  
Colour : Lt Grey  
End Use : Flooring  
Nominal Composition : PVC, Plasticizer, Filler, Polyester and Additives  
Nominal Mass per Unit Area/Density : 3100g/m2  
Nominal Thickness : 2.30mm

### AS/ISO 9239.1-2003

#### Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 12/12/2016  
Date Tested 16/12/2016

CHF Value	1	2	3	Mean
Length	9.1	-	-	- kW/m <sup>2</sup>
Width	6.6	8.2	7.8	7.5 kW/m <sup>2</sup>
Smoke Value	1	2	3	Mean
Length	48	-	-	- %min
Width	73	44	50	56 %min
Blistering				Yes

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2001 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was clamped as supplied by client prior to testing.

79014

16571

Page 1 of 1

© Australian Wool testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025  
- Chemical Testing  
- Mechanical Testing  
985

: Accreditation No. 983  
: Accreditation No.



Samples and their identifying descriptions have been provided by the client unless otherwise stated.  
AWTA  
Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall

0204/11/06

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)  
MANAGING DIRECTOR