

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Armstrong Flooring, Inc.

2500 Columbia Avenue, Lancaster, PA, United States

For the following product(s):

Polymeric Tile:

Migrations[®] BBT[™] & Migrations[®] BBT[™] with Diamond 10, Striations BBT[™] & Striations BBT[™] with Diamond 10

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore[®]

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-01635

Valid from: September 1, 2019 to August 31, 2020

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore[®] product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA