

# Emission Test Certificate

Friday 05<sup>th</sup> April 2019

Supplier: Armstrong Flooring Pty Ltd (29-39 Mills Road, Braeside, Victoria 3195, Australia)

Sample Description: Medintone Diamond 10\_AUS

Date Tested: March and April 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (28 days):


<b>Green Building Council of Australia Green Star Design &amp; As Built v1.1 - 13.1.2B &amp; 13.2 Green Star Interiors V1.1 - 12.1.2B</b>	<b>Medintone Diamond 10_AUS</b>
Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate: 0.014 mg/m <sup>2</sup> /hr
4-phenylcyclohexene Emission Rate Limit: <0.05 mg/m <sup>2</sup> /hr	4-phenylcyclohexene Emission Rate: <0.004 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: <0.1 mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: 0.011 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

CV190316