

# Emission Test Certificate

Tuesday, July 7<sup>th</sup> 2015

Supplier: Armstrong World Industries Pty Ltd (29-39 Mills Road, Braeside, VIC, 3195)

Sample Description: AUSTRALIS

Date Tested: June 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p><b>Green Building Council of Australia</b></p> <p><b>Green Star Office Design v3 IEQ-13</b></p>	<p><b>AUSTRALIS</b></p>
<p>Total Volatile Organic Compound Emission Rate limit &lt;0.5 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.013 mg/m<sup>2</sup>/hr (28 days)</p>
<p>4-phenylcyclohexene Emission Rate limit &lt;0.05 mg/m<sup>2</sup>/hr</p>	<p>4-phenylcyclohexene Emission Rate: &lt;0.002 mg/m<sup>2</sup>/hr (28 days)</p>
<p>Formaldehyde Emission Rate limit &lt;0.1 mg/m<sup>2</sup>/hr</p>	<p>Formaldehyde Emission Rate: &lt;0.004 mg/m<sup>2</sup>/hr (28 days)</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

CV150605