

Emission Test Certificate

Thursday, February 26th 2015

Supplier: Armstrong World Industries Pty Ltd (29-39 Mills Road, Braeside, VIC 3195)

Sample Description: Accolade Plus / Infinity / Expressions

Date Tested: February 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Specification Green Building Council of Australia Green Star Office Design v3 IEQ-13	Accolade Plus / Infinity / Expressions
Total Volatile Organic Compound Emission Rate limit: $<0.5 \text{ mg/m}^2/\text{hr}$ $<500\mu\text{g/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate (28 Days): $0.019 \text{ mg/m}^2/\text{hr}$ $19\mu\text{g/m}^2/\text{hr}$



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV150109a